

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10304	Main Street: BEAUGARD_DR	Cross Street: TUCKASEEGEE_RD	Location: S
ADA ID: 27F97335C1C8	Overall Compliance: No	Severity Score: 85	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Boarding Area. Remove & Replace Sidewalk To Boarding Area. Provide Clear Floor Space.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2, 810.2.3, 810.3, R302, R302.6, R308.1.1, R404.1

CATS Stop ID: **32640**

CATS Stop Description: **Tuckaseegee Rd & Karendale Ave**

CATS Route ID: **8**

CATS Route Name: **Tuckaseegee Road**

Total Cost: \$ **1850.00**

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
No	PAR 1 Slope %	3.5
Yes	PAR 1 XSlope %	1.4
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	0.2
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

