


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 15584	Main Street: BONLYN_DR	Cross Street: E_W_T_HARRIS_BV	Location: SE
ADA ID: 28F1A9604C33	Overall Compliance: No	Severity Score: 55	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Boarding Area. Remove & Replace Sidewalk To Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2, 810.2.3, R302, R302.5, R308.1.1

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	48.0
Yes	PAR 1 Slope %	2.6
No	PAR 1 XSlope %	3.9
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	3.0
N/A	Shelter	No
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	70.0
Yes	Clear Floor Space Length (in)	60.0
Yes	Clear Floor Space Slope %	1.9
Yes	Clear Floor Space XSlope %	1.9
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 07570

CATS Stop Description: WT Harris Blvd & Bonlyn Dr

CATS Route ID: 221, 3

CATS Route Name: Multiple

Total Cost: \$ 1400.00

