


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10013202	Main Street: STATESVILLE_RD	Cross Street: N/A	Location: W
ADA ID: 2C3E9F6B1B2E	Overall Compliance: No	Severity Score: 35	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

810.3, R404.1

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	244.0
Yes	Boarding Area Length (in)	104.0
Yes	Boarding Area Slope %	1.6
Yes	Boarding Area XSlope %	0.3
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.3
Yes	PAR 1 XSlope %	1.5
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	1.0
Yes	PAR 2 XSlope %	0.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.2
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	95.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 46692

CATS Stop Description: Statesville Rd & Sunset Rd

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$ 2450.00

