


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: -9999	Main Street: S Main St	Cross Street: N/A	Location: W
ADA ID: 2DDE34EF5543	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Clear Floor Space. Remove
or Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**810.2.2, 810.2.4, 810.3, R308.1.1.1,
R308.1.1.2, R404.1**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	52.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	9.0
Yes	Boarding Area XSlope %	1.8
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	96.0
Yes	PAR 1 Slope %	1.6
Yes	PAR 1 XSlope %	1.4
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	96.0
Yes	PAR 2 Slope %	0.8
Yes	PAR 2 XSlope %	0.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.9
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	90.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: **40320**

CATS Stop Description: **Main St & Concord Rd**

CATS Route ID: **97, 99**

CATS Route Name: **Multiple**

Total Cost: \$ **3200.00**

