


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10013227	Main Street: THE_PLAZA	Cross Street: N/A	Location: S
ADA ID: 34991AD52DA8	Overall Compliance: No	Severity Score: 40	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

NO CATS ID LISTED

PROW/ADA:

810.2.2, R308.1.1.1

CATS Stop ID: 31850

CATS Stop Description: **The Plaza & Barrington Dr**

CATS Route ID: 23

CATS Route Name: **Shamrock Drive**

Total Cost: \$ 750.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	67.0
Yes	Boarding Area Slope %	1.0
Yes	Boarding Area XSlope %	0.2
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.2
Yes	PAR 1 XSlope %	1.0
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	1.0
Yes	PAR 2 XSlope %	1.0
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.4
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	90.0
N/A	Bench?	No
Yes	Protruding Objects?	No

