


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 22411	Main Street: PARKWOOD_AV	Cross Street: UMSTEAD_ST	Location: N
ADA ID: 3826076F3928	Overall Compliance: No	Severity Score: 15	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove or Relocate
Protruding Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.3, 810.2.4, R302, R302.5,
R302.6, R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	4.3
Yes	Boarding Area XSlope %	1.9
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	48.0
Yes	PAR 1 Slope %	1.9
No	PAR 1 XSlope %	4.3
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	48.0
Yes	PAR 2 Slope %	1.8
No	PAR 2 XSlope %	4.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.6
N/A	Shelter	No
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	153.0
Yes	Clear Floor Space Length (in)	132.0
Yes	Clear Floor Space Slope %	0.4
Yes	Clear Floor Space XSlope %	0.9
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	90.5
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 21560

CATS Stop Description: **Parkwood Ave & Umstead St**

CATS Route ID: 4

CATS Route Name: **Belmont**

Total Cost: \$ 4150.00

