


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10014433	Main Street: GRIER_RD	Cross Street: N/A	Location: S
ADA ID: 3B009D126B3F	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove & Replace Clear Floor Space.

Surveyor Notes:

N/A

PROW/ADA:

305.3, 402.2, 810.2.3, 810.3, R302, R302.5, R302.6, R404.1, R404.3

CATS Stop ID: **45869**

CATS Stop Description: **Grier Rd & WT Harris Blvd**

CATS Route ID: **23, 29**

CATS Route Name: **Multiple**

Total Cost: \$ **1900.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	198.0
Yes	Boarding Area Slope %	1.2
Yes	Boarding Area XSlope %	0.2
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	59.0
No	PAR 1 Slope %	3.0
Yes	PAR 1 XSlope %	0.0
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
No	PAR 2 Slope %	3.9
Yes	PAR 2 XSlope %	0.2
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.0
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	70.0
No	Clear Floor Space Length (in)	6.2
Yes	Clear Floor Space Slope %	1.4
Yes	Clear Floor Space XSlope %	1.3
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

