


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10033477	Main Street: OLD_PINEVILLE_RD	Cross Street: N/A	Location: E
ADA ID: 3C2FE9760D41	Overall Compliance: No	Severity Score: 20	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

305.2, 305.3, 402.2, 810.2.3, 810.3, R302, R302.5, R302.6, R404.1, R404.2, R404.3

CATS Stop ID: **46035**
CATS Stop Description: **Archdale Station**
CATS Route ID: **57**
CATS Route Name: **Archdale**

Total Cost: \$ **3200.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	130.0
Yes	Boarding Area Length (in)	140.0
Yes	Boarding Area Slope %	1.4
Yes	Boarding Area XSlope %	1.8
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	65.5
Yes	PAR 1 Slope %	1.8
Yes	PAR 1 XSlope %	1.4
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	65.5
No	PAR 2 Slope %	3.7
No	PAR 2 XSlope %	5.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.3
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	68.0
No	Clear Floor Space Length (in)	41.0
Yes	Clear Floor Space Slope %	0.2
No	Clear Floor Space XSlope %	3.0
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

