


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                        |                                         |              |
|-----------------------------------------|------------------------|-----------------------------------------|--------------|
| Intersection ID: 10033982               | Main Street: PARK_RD   | Cross Street: N/A                       | Location: SE |
| ADA ID: 3D075A25D5A3                    | Overall Compliance: No | Severity Score: 40                      |              |
| Codes/Mitigation Info/Possible Solution |                        | Field Measurements/Component Compliance |              |



Possible Solutions:

**Remove & Replace Boarding Area.  
Provide Clear Floor Space.**

Surveyor Notes:

**N/A**

PROW/ADA:

**810.2.2, 810.3, R308.1.1.1, R404.1**

| Compliance | Description                     | Data |
|------------|---------------------------------|------|
| Yes        | Boarding Area                   | Yes  |
| Yes        | Boarding Area Width (in)        | 63.0 |
| No         | Boarding Area Length (in)       | 60.0 |
| Yes        | Boarding Area Slope %           | 1.3  |
| Yes        | Boarding Area XSlope %          | 0.2  |
| Yes        | PAR 1 Exist?                    | Yes  |
| Yes        | PAR 1 Width (in)                | 60.0 |
| Yes        | PAR 1 Slope %                   | 0.1  |
| Yes        | PAR 1 XSlope %                  | 1.4  |
| N/A        | PAR 1 XSlope Location           | Perp |
| Yes        | PAR 2 Exist?                    | Yes  |
| Yes        | PAR 2 Width (in)                | 60.0 |
| Yes        | PAR 2 Slope %                   | 0.6  |
| Yes        | PAR 2 XSlope %                  | 1.5  |
| N/A        | PAR 2 XSlope Location           | Perp |
| Yes        | Boarding Area Connected to PAR? | Yes  |
| N/A        | Road Slope %                    | 0.4  |
| N/A        | Shelter                         | No   |
| No         | Clear Floor Space               | No   |
| N/A        | Clear Floor Space Shelter       | No   |
| N/A        | Clear Floor Space Width (in)    | N/A  |
| N/A        | Clear Floor Space Length (in)   | N/A  |
| N/A        | Clear Floor Space Slope %       | N/A  |
| N/A        | Clear Floor Space XSlope %      | N/A  |
| N/A        | Alcove Condition?               | No   |
| Yes        | Transit Sign?                   | Yes  |
| Yes        | Transit Sign Height (in)        | 96.0 |
| N/A        | Bench?                          | Yes  |
| Yes        | Protruding Objects?             | No   |

CATS Stop ID: 21251

CATS Stop Description: **Park Rd @ Southminister Retirement Dr**

CATS Route ID: 19, 43

CATS Route Name: **Multiple**

Total Cost: \$ 1200.00

