


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                           |                                |                    |             |
|---------------------------|--------------------------------|--------------------|-------------|
| Intersection ID: 10012689 | Main Street: N_SHARON_AMITY_RD | Cross Street: N/A  | Location: E |
| ADA ID: 3E4688B8F611      | Overall Compliance: No         | Severity Score: 50 |             |

| Codes/Mitigation Info/Possible Solution | Field Measurements/Component Compliance |
|-----------------------------------------|-----------------------------------------|
|-----------------------------------------|-----------------------------------------|



Possible Solutions:

**Remove & Replace Boarding Area.  
Remove & Replace Sidewalk To  
Boarding Area. Remove or Relocate  
Protruding Objects/Obstructions.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, 810.2.2, 810.2.3, 810.2.4, R302,  
R302.5, R302.6, R308.1.1.1,  
R308.1.1.2**

| Compliance | Description                     | Data |
|------------|---------------------------------|------|
| Yes        | Boarding Area                   | Yes  |
| Yes        | Boarding Area Width (in)        | 60.0 |
| No         | Boarding Area Length (in)       | 66.0 |
| No         | Boarding Area Slope %           | 5.3  |
| No         | Boarding Area XSlope %          | 2.3  |
| No         | PAR 1 Exist?                    | Yes  |
| Yes        | PAR 1 Width (in)                | 60.0 |
| No         | PAR 1 Slope %                   | 2.3  |
| No         | PAR 1 XSlope %                  | 5.3  |
| N/A        | PAR 1 XSlope Location           | Perp |
| No         | PAR 2 Exist?                    | Yes  |
| Yes        | PAR 2 Width (in)                | 60.0 |
| Yes        | PAR 2 Slope %                   | 0.3  |
| No         | PAR 2 XSlope %                  | 5.3  |
| N/A        | PAR 2 XSlope Location           | Perp |
| Yes        | Boarding Area Connected to PAR? | Yes  |
| N/A        | Road Slope %                    | 1.0  |
| N/A        | Shelter                         | No   |
| N/A        | Clear Floor Space               | No   |
| N/A        | Clear Floor Space Shelter       | No   |
| N/A        | Clear Floor Space Width (in)    | N/A  |
| N/A        | Clear Floor Space Length (in)   | N/A  |
| N/A        | Clear Floor Space Slope %       | N/A  |
| N/A        | Clear Floor Space XSlope %      | N/A  |
| N/A        | Alcove Condition?               | No   |
| Yes        | Transit Sign?                   | Yes  |
| Yes        | Transit Sign Height (in)        | 90.0 |
| N/A        | Bench?                          | No   |
| No         | Protruding Objects?             | Yes  |

CATS Stop ID: 27820

CATS Stop Description: Sharon Amity Rd & Albemarle Rd

CATS Route ID: 17, 28, 29

CATS Route Name: Multiple

Total Cost: \$ 4150.00

