

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 13644	Main Street: BEECH_NUT_RD	Cross Street: WEST_BV	Location: S
ADA ID: 3E60198E4185	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 403.5.1, 810.2.2, 810.2.3,
810.2.4, R302, R302.3, R302.5,
R302.6, R308.1.1.1, R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	54.0
Yes	Boarding Area Slope %	1.6
No	Boarding Area XSlope %	2.8
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	46.0
No	PAR 1 Slope %	2.8
Yes	PAR 1 XSlope %	1.6
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
No	PAR 2 Width (in)	46.0
No	PAR 2 Slope %	3.7
No	PAR 2 XSlope %	2.1
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.3
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	99.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 38460

CATS Stop Description: West Blvd & Beech Nut Rd

CATS Route ID: 10, 30

CATS Route Name: Multiple

Total Cost: \$ 2150.00

