


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10016641	Main Street: THE_PLAZA	Cross Street: N/A	Location: E
ADA ID: 3EA948CD7748	Overall Compliance: No	Severity Score: 20	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Clear Floor
Space.**

Surveyor Notes:

N/A

PROW/ADA:

**305.3, 810.2.4, 810.3, R308.1.1.2,
R404.1, R404.3**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	78.0
Yes	Boarding Area Length (in)	102.0
No	Boarding Area Slope %	3.6
Yes	Boarding Area XSlope %	0.8
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.5
Yes	PAR 1 XSlope %	0.6
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.5
Yes	PAR 2 XSlope %	1.0
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.6
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	46.5
No	Clear Floor Space Length (in)	45.5
Yes	Clear Floor Space Slope %	1.0
Yes	Clear Floor Space XSlope %	0.7
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 31400

CATS Stop Description: The Plaza & 36th St

CATS Route ID: 23, 3, 4

CATS Route Name: Multiple

Total Cost: \$ 1250.00

