


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10031952	Main Street: MONROE_RD	Cross Street: N/A	Location: NE
ADA ID: 3FD26A30467A	Overall Compliance: No	Severity Score: 60	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Provide Clear Floor
Space.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 403.5.1, 810.2.2, 810.2.3,
810.2.4, 810.3, R302, R302.3, R302.6,
R308.1.1.1, R308.1.1.2, R404.1**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	62.0
No	Boarding Area Length (in)	65.0
No	Boarding Area Slope %	5.9
Yes	Boarding Area XSlope %	1.2
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	44.0
No	PAR 1 Slope %	6.1
Yes	PAR 1 XSlope %	0.9
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	59.0
Yes	PAR 2 Slope %	0.3
No	PAR 2 XSlope %	6.3
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.6
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 15900

CATS Stop Description: **Monroe Rd & Wendover Rd**

CATS Route ID: 27

CATS Route Name: **Monroe Road**

Total Cost: \$ 2600.00

