


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 5781	Main Street: NEAL_RD	Cross Street: IBM_DR	Location: W
ADA ID: 40985CE81085	Overall Compliance: No	Severity Score: 25	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

WIDTH BETWEEN TRASH CAN AND CURB 42.0

PROW/ADA:

305.2, 402.2, 810.2.3, 810.3, R302, R302.5, R302.6, R404.1, R404.2

CATS Stop ID: **45325**
 CATS Stop Description: **IBM Dr & Neal Rd**
 CATS Route ID: **54**
 CATS Route Name: **URP**

Total Cost: \$ **3200.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	112.0
Yes	Boarding Area Slope %	1.6
Yes	Boarding Area XSlope %	4.0
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	78.0
Yes	PAR 1 Slope %	4.0
Yes	PAR 1 XSlope %	1.6
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	78.0
No	PAR 2 Slope %	5.3
No	PAR 2 XSlope %	2.2
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	4.8
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	77.0
Yes	Clear Floor Space Length (in)	67.0
Yes	Clear Floor Space Slope %	1.7
No	Clear Floor Space XSlope %	4.2
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

