


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10020722	Main Street: BEATTIES_FORD_RD	Cross Street: HOLLY_ST	Location: W
ADA ID: 413EBD351D14	Overall Compliance: No	Severity Score: 10	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

305.3, 402.2, 810.2.3, 810.3, R302, R302.6, R404.1, R404.3

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	1.9
Yes	Boarding Area XSlope %	0.6
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	71.0
Yes	PAR 1 Slope %	0.7
Yes	PAR 1 XSlope %	1.6
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	71.0
Yes	PAR 2 Slope %	0.8
No	PAR 2 XSlope %	2.3
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.9
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	51.0
No	Clear Floor Space Length (in)	34.0
Yes	Clear Floor Space Slope %	1.8
Yes	Clear Floor Space XSlope %	0.2
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.5
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 02670

CATS Stop Description: Beatties Ford Rd & Montana Dr

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$ 3200.00

