


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10033924	Main Street: PARK_RD	Cross Street: N/A	Location: W
ADA ID: 41AE329BF24A	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

810.2.2, R308.1.1.1

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	94.0
Yes	Boarding Area Slope %	0.6
Yes	Boarding Area XSlope %	3.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	88.0
Yes	PAR 1 Slope %	2.8
Yes	PAR 1 XSlope %	1.9
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	88.0
Yes	PAR 2 Slope %	2.8
Yes	PAR 2 XSlope %	0.0
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	3.4
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	89.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 20570

CATS Stop Description: **Park Rd & McDonald Ave**

CATS Route ID: 19

CATS Route Name: **Park Road**

Total Cost: \$ 750.00

