


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10035523	Main Street: REA_RD	Cross Street: N/A	Location: W
ADA ID: 41D9FB7D46BE	Overall Compliance: No	Severity Score: 50	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, R302, R302.5, R302.6

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	131.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	1.7
Yes	Boarding Area XSlope %	5.4
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	70.0
No	PAR 1 Slope %	5.8
Yes	PAR 1 XSlope %	0.9
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	70.0
No	PAR 2 Slope %	6.3
No	PAR 2 XSlope %	2.3
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	5.6
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	101.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 37700

CATS Stop Description: **Rea Rd & Carmel Estates Rd**

CATS Route ID: 62x

CATS Route Name: **Rea Road Express**

Total Cost: \$ 1400.00

