


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10040510	Main Street: W_4TH_ST	Cross Street: N/A	Location: E
ADA ID: 439B474550A3	Overall Compliance: N/A	Severity Score: 40	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

N/A

Surveyor Notes:

**BOARDING AREA & PAR 1 PAVERS,
PAR 2 CONC**

PROW/ADA:

N/A

CATS Stop ID: 59660
CATS Stop Description: 4th St & Graham St
CATS Route ID: 22, 34, 41x, 48x, 7
CATS Route Name: Multiple

Total Cost: \$0.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	103.0
Yes	Boarding Area Slope %	0.7
Yes	Boarding Area XSlope %	0.2
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	96.0
Yes	PAR 1 Slope %	1.3
Yes	PAR 1 XSlope %	0.1
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	96.0
Yes	PAR 2 Slope %	0.9
Yes	PAR 2 XSlope %	1.0
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.9
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	90.0
N/A	Bench?	No
Yes	Protruding Objects?	No

