


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10017663	Main Street: STATESVILLE_AV	Cross Street: N/A	Location: W
ADA ID: 4898843ABD2F	Overall Compliance: No	Severity Score: 25	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space. Remove or
Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

BOARDING AREA IS RAMP

PROW/ADA:

**305.2, 305.3, 402.2, 810.2.3, 810.2.4,
810.3, R302, R302.5, R308.1.1.2,
R404.1, R404.2, R404.3**

CATS Stop ID: 30460

CATS Stop Description: Statesville Ave & Kohler Ave

CATS Route ID: 21

CATS Route Name: Statesville Ave

Total Cost: \$ 3950.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	186.0
Yes	Boarding Area Length (in)	108.0
No	Boarding Area Slope %	7.0
Yes	Boarding Area XSlope %	2.0
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	96.0
Yes	PAR 1 Slope %	1.2
No	PAR 1 XSlope %	2.8
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	96.0
Yes	PAR 2 Slope %	1.8
Yes	PAR 2 XSlope %	1.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.4
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	118.0
No	Clear Floor Space Length (in)	26.0
No	Clear Floor Space Slope %	4.2
No	Clear Floor Space XSlope %	3.0
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	90.5
N/A	Bench?	Yes
No	Protruding Objects?	Yes

