Access Compliance Report
Public Rights-of-Way
(Transit Stops)

Intersection ID: -9999 **Main Street:** N Main St **Cross Street:** N/A **Location:** E

ADA ID: 49028BE8AC2E **Overall Compliance:** No **Severity Score:** 85

Codes/Mitigation Info/Possible Solution



Possible Solutions:

Provide Boarding Area. Remove & Replace Sidewalk To Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2, 810.2.3, R302, R302.5, R302.6, R308.1.1

CATS Stop ID: **40340**

CATS Stop Description: **Main St & Griffith St**

CATS Route ID: **97, 99**

CATS Route Name: **Multiple**

Total Cost: **$ 2100.00**

Field Measurements/Component Compliance

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	77.0
Yes	PAR 1 Slope %	1.6
No	PAR 1 XSlope %	3.4
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	77.0
No	PAR 2 Slope %	2.9
No	PAR 2 XSlope %	4.1
N/A	PAR 2 XSlope Location	Perp
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	1.7
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.0
N/A	Bench?	No
Yes	Protruding Objects?	No