

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10015662	Main Street: STATESVILLE_RD	Cross Street: N/A	Location: E
ADA ID: 4B6DD2D78ECA	Overall Compliance: No	Severity Score: 10	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, R302, R302.6

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	66.0
Yes	Boarding Area Length (in)	114.0
Yes	Boarding Area Slope %	1.5
Yes	Boarding Area XSlope %	0.5
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	83.0
Yes	PAR 1 Slope %	0.5
Yes	PAR 1 XSlope %	1.5
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	83.0
Yes	PAR 2 Slope %	1.2
No	PAR 2 XSlope %	3.0
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.9
N/A	Shelter	No
N/A	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	66.0
N/A	Clear Floor Space Length (in)	23.5
N/A	Clear Floor Space Slope %	1.3
N/A	Clear Floor Space XSlope %	1.1
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.5
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 30620

CATS Stop Description: Statesville Rd & Starita Rd

CATS Route ID: 21

CATS Route Name: Statesville Ave

Total Cost: \$ 700.00

