


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10015813	Main Street: BARRINGTON_DR	Cross Street: N/A	Location: W
ADA ID: 4BD4391C03E0	Overall Compliance: No	Severity Score: 60	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 403.5.1, 810.2.2, 810.2.3,
810.2.4, R302, R302.3, R302.6,
R308.1.1.1, R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	43.0
No	Boarding Area Length (in)	74.0
No	Boarding Area Slope %	3.8
No	Boarding Area XSlope %	3.3
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	47.0
No	PAR 1 Slope %	2.4
Yes	PAR 1 XSlope %	1.6
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
No	PAR 2 Width (in)	47.0
Yes	PAR 2 Slope %	0.5
Yes	PAR 2 XSlope %	1.3
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.3
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 02190

CATS Stop Description: Barrington Dr & Milton Rd

CATS Route ID: 29

CATS Route Name: UNCC / JW Clay

Total Cost: \$ 2150.00

