


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10036508	Main Street: ROZZELLES_FERRY_RD	Cross Street: N/A	Location: SE
ADA ID: 4D328DAAFA2F	Overall Compliance: No	Severity Score: 25	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

CLEAR SPACE SLOPES VERIFIED

PROW/ADA:

305.2, 402.2, 810.2.3, 810.3, R302, R302.6, R404.1, R404.2

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	74.0
Yes	Boarding Area Length (in)	105.0
Yes	Boarding Area Slope %	0.0
Yes	Boarding Area XSlope %	1.2
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	59.0
No	PAR 1 Slope %	12.2
Yes	PAR 1 XSlope %	1.0
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.4
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	71.0
Yes	Clear Floor Space Length (in)	92.0
No	Clear Floor Space Slope %	2.1
No	Clear Floor Space XSlope %	6.7
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 25010

CATS Stop Description: Rozzelles Ferry Rd & Lander St

CATS Route ID: 1

CATS Route Name: Mt Holly Valleydale

Total Cost: \$ 3200.00

