

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10020762	Main Street: BEATTIES_FORD_RD	Cross Street: N/A	Location: W
ADA ID: 4DC176C546D0	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Clear Floor
Space. Remove or Relocate
Protruding Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 810.2.2, 810.3, R308.1.1.1,
R404.1, R404.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	44.0
Yes	Boarding Area Length (in)	108.0
Yes	Boarding Area Slope %	1.9
Yes	Boarding Area XSlope %	0.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.1
Yes	PAR 1 XSlope %	1.9
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.6
Yes	PAR 2 XSlope %	0.7
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.2
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	44.0
Yes	Clear Floor Space Length (in)	67.0
No	Clear Floor Space Slope %	2.3
Yes	Clear Floor Space XSlope %	0.5
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	86.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 02790

CATS Stop Description: Beatties Ford Rd & Griers Grove Rd

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$ 3250.00

