


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10040508	Main Street: W_4TH_ST	Cross Street: S_CHURCH_ST	Location: E
ADA ID: 5416F7BA2ECA	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.2, 810.2.3, 810.2.4, R302,
R302.5, R308.1.1.1, R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	49.5
No	Boarding Area Length (in)	75.0
No	Boarding Area Slope %	2.3
Yes	Boarding Area XSlope %	1.4
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	49.5
Yes	PAR 1 Slope %	1.4
No	PAR 1 XSlope %	2.3
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	49.5
Yes	PAR 2 Slope %	1.4
Yes	PAR 2 XSlope %	1.7
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.6
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	101.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 38420

CATS Stop Description: 4th St & Poplar St

CATS Route ID: 22, 34, 41x, 48x, 7, 77x, 8, 82x, 85x, 88x

CATS Route Name: Multiple

Total Cost: \$ 1450.00

