


# Access Compliance Report

## Public Rights-of-Way

### (Transit Stops)

|                                         |                            |                                         |              |
|-----------------------------------------|----------------------------|-----------------------------------------|--------------|
| Intersection ID: 18191                  | Main Street: E_WOODLAWN_RD | Cross Street: LONGWOOD_DR               | Location: NE |
| ADA ID: 55D0B2624D86                    | Overall Compliance: No     | Severity Score: 90                      |              |
| Codes/Mitigation Info/Possible Solution |                            | Field Measurements/Component Compliance |              |



Possible Solutions:

**Provide Boarding Area. Provide Sidewalk Connection to Boarding Area.**

Surveyor Notes:

**N/A**

PROW/ADA:

**810.2, 810.2.3, R302, R308.1.1**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| No         | Boarding Area                   | No    |
| N/A        | Boarding Area Width (in)        | N/A   |
| N/A        | Boarding Area Length (in)       | N/A   |
| N/A        | Boarding Area Slope %           | N/A   |
| N/A        | Boarding Area XSlope %          | N/A   |
| Yes        | PAR 1 Exist?                    | Yes   |
| Yes        | PAR 1 Width (in)                | 54.0  |
| Yes        | PAR 1 Slope %                   | 2.8   |
| Yes        | PAR 1 XSlope %                  | 1.0   |
| N/A        | PAR 1 XSlope Location           | Perp  |
| Yes        | PAR 2 Exist?                    | Yes   |
| Yes        | PAR 2 Width (in)                | 54.0  |
| Yes        | PAR 2 Slope %                   | 4.8   |
| Yes        | PAR 2 XSlope %                  | 1.4   |
| N/A        | PAR 2 XSlope Location           | Perp  |
| No         | Boarding Area Connected to PAR? | No    |
| N/A        | Road Slope %                    | 4.9   |
| N/A        | Shelter                         | No    |
| N/A        | Clear Floor Space               | No    |
| N/A        | Clear Floor Space Shelter       | No    |
| N/A        | Clear Floor Space Width (in)    | N/A   |
| N/A        | Clear Floor Space Length (in)   | N/A   |
| N/A        | Clear Floor Space Slope %       | N/A   |
| N/A        | Clear Floor Space XSlope %      | N/A   |
| N/A        | Alcove Condition?               | No    |
| Yes        | Transit Sign?                   | Yes   |
| Yes        | Transit Sign Height (in)        | 102.0 |
| N/A        | Bench?                          | No    |
| Yes        | Protruding Objects?             | No    |

CATS Stop ID: 35770

CATS Stop Description: Woodlawn Rd & Castlewood Rd

CATS Route ID: 30

CATS Route Name: Woodlawn Crosstown

Total Cost: \$ 1450.00

