


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10012679	Main Street: N_GRAHAM_ST	Cross Street: N/A	Location: E
ADA ID: 55E3049D0B03	Overall Compliance: No	Severity Score: 20	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space. Remove or
Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

CATS ID NOT LEGIBLE.

PROW/ADA:

**305.2, 305.3, 402.2, 810.2.3, 810.2.4,
810.3, R302, R302.5, R302.6,
R308.1.1.2, R404.1, R404.2, R404.3**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	120.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	3.6
Yes	Boarding Area XSlope %	1.8
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.2
No	PAR 1 XSlope %	4.9
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.9
No	PAR 2 XSlope %	3.1
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.0
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	49.0
No	Clear Floor Space Length (in)	32.0
No	Clear Floor Space Slope %	2.1
Yes	Clear Floor Space XSlope %	1.1
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 17780

CATS Stop Description: **Graham St & 24th St**

CATS Route ID: 22

CATS Route Name: **Graham Street**

Total Cost: \$ 4650.00

