


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10020375	Main Street: BALLANTYNE_CORPORATE_PL	Cross Street: N/A	Location: SE
ADA ID: 5778E1C0A30D	Overall Compliance: No	Severity Score: 20	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Clear Floor
Space. Remove or Relocate
Protruding Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 810.2.2, 810.2.4, 810.3,
R308.1.1.1, R308.1.1.2, R404.1,
R404.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	59.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	2.3
Yes	Boarding Area XSlope %	1.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	48.0
Yes	PAR 1 Slope %	1.2
Yes	PAR 1 XSlope %	0.8
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	48.0
Yes	PAR 2 Slope %	1.6
Yes	PAR 2 XSlope %	1.5
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.1
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	66.0
Yes	Clear Floor Space Length (in)	56.0
Yes	Clear Floor Space Slope %	1.1
No	Clear Floor Space XSlope %	2.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: **46330**

CATS Stop Description: **Ballantyne Corporate Pl & Brixham Hill Ave**

CATS Route ID: **43**

CATS Route Name: **Ballantyne**

Total Cost: \$ **3250.00**

