


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 18085	Main Street: RANDOLPH_PARK_APTS_DR	Cross Street: RANDOLPH_RD	Location: NE
ADA ID: 5A21BADF0A5A	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

STOP NOT IN SERVICE

PROW/ADA:

**402.2, 810.2.2, 810.2.3, 810.2.4, R302,
R302.5, R302.6, R308.1.1.1,
R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	77.0
No	Boarding Area Slope %	2.9
Yes	Boarding Area XSlope %	0.4
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	70.0
Yes	PAR 1 Slope %	0.9
No	PAR 1 XSlope %	2.5
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	70.0
No	PAR 2 Slope %	2.6
No	PAR 2 XSlope %	2.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.1
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	95.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 24050

CATS Stop Description: Randolph Rd & Gaynor Rd

CATS Route ID: 62x

CATS Route Name: Rea Road Express

Total Cost: \$ 2150.00

