


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 12455	Main Street: W_3RD_ST	Cross Street: S_TRYON_ST	Location: W
ADA ID: 5BA34627D5D6	Overall Compliance: N/A	Severity Score: 40	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

N/A

Surveyor Notes:

PAR WIDTH WITHIN LARGE LANDING

PROW/ADA:

N/A

CATS Stop ID: 45010

CATS Stop Description: 3rd St & Tryon St

CATS Route ID: 41x, 48x, 53x, 61x, 62x, 77x, 82x, 85x, 88x

CATS Route Name: Multiple

Total Cost: \$0.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	140.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	1.9
Yes	Boarding Area XSlope %	0.5
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.2
Yes	PAR 1 XSlope %	0.8
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.7
Yes	PAR 2 XSlope %	1.4
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.3
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	No
Yes	Protruding Objects?	No

