


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 10017914	Main Street: SHAMROCK_DR	Cross Street: FINCHLEY_DR	Location: N
ADA ID: 5E7AB6A61EC2	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

305.2, 810.3, R404.1, R404.2

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	115.0
Yes	Boarding Area Slope %	0.5
Yes	Boarding Area XSlope %	2.3
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	59.0
Yes	PAR 1 Slope %	2.3
Yes	PAR 1 XSlope %	0.5
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	59.0
Yes	PAR 2 Slope %	2.6
Yes	PAR 2 XSlope %	0.5
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.6
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	64.0
Yes	Clear Floor Space Length (in)	48.0
No	Clear Floor Space Slope %	2.3
No	Clear Floor Space XSlope %	3.1
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	98.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 27275

CATS Stop Description: Shamrock Dr & Finchley Rd

CATS Route ID: 23

CATS Route Name: Shamrock Drive

Total Cost: \$ 2500.00

