

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10906	Main Street: W_TRADE_ST	Cross Street: MONTGOMERY_ST	Location: NE
ADA ID: 618FB67E3AF4	Overall Compliance: No	Severity Score: 25	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 305.3, 402.2, 810.2.3, 810.2.4,
810.3, R302, R302.5, R308.1.1.2,
R404.1, R404.2, R404.3**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	4.8
Yes	Boarding Area XSlope %	3.4
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	3.5
No	PAR 1 XSlope %	4.0
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	3.6
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
No	Clear Floor Space Width (in)	N/A
No	Clear Floor Space Length (in)	N/A
No	Clear Floor Space Slope %	N/A
No	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 33840

CATS Stop Description: Trade St & Montgomery St

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$ 1950.00

