


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10023536	Main Street: CLANTON_RD	Cross Street: N/A	Location: W
ADA ID: 61D0F996476F	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

**810.2.2, 810.2.4, R308.1.1.1,
R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
No	Boarding Area Width (in)	47.5
No	Boarding Area Length (in)	55.0
No	Boarding Area Slope %	3.7
No	Boarding Area XSlope %	2.9
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	51.0
Yes	PAR 1 Slope %	0.0
Yes	PAR 1 XSlope %	1.2
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	51.0
Yes	PAR 2 Slope %	0.9
Yes	PAR 2 XSlope %	0.5
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.7
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 05940

CATS Stop Description: Clanton Rd & Sargeant Dr

CATS Route ID: 30

CATS Route Name: Woodlawn Crosstown

Total Cost: \$ 750.00

