


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10016972	Main Street: STATESVILLE_AV	Cross Street: N/A	Location: W
ADA ID: 61E29361D8B2	Overall Compliance: No	Severity Score: 40	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 402.2, 810.2.2, 810.2.3,
810.2.4, 810.3, R302, R302.5,
R308.1.1.1, R308.1.1.2, R404.1,
R404.2**

CATS Stop ID: **30440**

CATS Stop Description: **Statesville Ave & Woodward Ave**

CATS Route ID: **21**

CATS Route Name: **Statesville Ave**

Total Cost: \$ **1950.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	63.0
No	Boarding Area Slope %	6.0
Yes	Boarding Area XSlope %	2.7
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	2.6
No	PAR 1 XSlope %	3.8
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	2.8
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	96.0
Yes	Clear Floor Space Length (in)	60.0
Yes	Clear Floor Space Slope %	2.0
No	Clear Floor Space XSlope %	3.1
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	89.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

