


# Access Compliance Report Public Rights-of-Way (Transit Stops)

| Intersection ID: 10025355               | Main Street: E_7TH_ST  | Cross Street: N/A                       | Location: NE |
|-----------------------------------------|------------------------|-----------------------------------------|--------------|
| ADA ID: 62F268D70B2F                    | Overall Compliance: No | Severity Score: 55                      |              |
| Codes/Mitigation Info/Possible Solution |                        | Field Measurements/Component Compliance |              |



Possible Solutions:

**Remove & Replace Boarding Area.  
Remove & Replace Sidewalk To  
Boarding Area.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, 810.2.3, 810.2.4, R302, R302.5,  
R308.1.1.2**

| Compliance | Description                     | Data |
|------------|---------------------------------|------|
| Yes        | Boarding Area                   | Yes  |
| Yes        | Boarding Area Width (in)        | 71.0 |
| Yes        | Boarding Area Length (in)       | 96.0 |
| No         | Boarding Area Slope %           | 5.0  |
| No         | Boarding Area XSlope %          | 2.8  |
| Yes        | PAR 1 Exist?                    | Yes  |
| Yes        | PAR 1 Width (in)                | 58.5 |
| Yes        | PAR 1 Slope %                   | 2.3  |
| Yes        | PAR 1 XSlope %                  | 1.6  |
| N/A        | PAR 1 XSlope Location           | Perp |
| No         | PAR 2 Exist?                    | Yes  |
| Yes        | PAR 2 Width (in)                | 58.5 |
| No         | PAR 2 Slope %                   | 2.7  |
| Yes        | PAR 2 XSlope %                  | 0.2  |
| N/A        | PAR 2 XSlope Location           | Perp |
| Yes        | Boarding Area Connected to PAR? | Yes  |
| N/A        | Road Slope %                    | 2.3  |
| N/A        | Shelter                         | No   |
| N/A        | Clear Floor Space               | No   |
| N/A        | Clear Floor Space Shelter       | No   |
| N/A        | Clear Floor Space Width (in)    | N/A  |
| N/A        | Clear Floor Space Length (in)   | N/A  |
| N/A        | Clear Floor Space Slope %       | N/A  |
| N/A        | Clear Floor Space XSlope %      | N/A  |
| N/A        | Alcove Condition?               | No   |
| Yes        | Transit Sign?                   | Yes  |
| Yes        | Transit Sign Height (in)        | 86.0 |
| N/A        | Bench?                          | No   |
| Yes        | Protruding Objects?             | No   |

CATS Stop ID: 08020

CATS Stop Description: 7th St & Caswell Rd

CATS Route ID: 27

CATS Route Name: Monroe Road

Total Cost: \$ 1450.00

