


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10032772	Main Street: N_TRYON_ST	Cross Street: N/A	Location: S
ADA ID: 6426E44FF2FF	Overall Compliance: No	Severity Score: 10	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, R302, R302.5

CATS Stop ID: **18150**
 CATS Stop Description: **Tryon St & 8th St**
 CATS Route ID: **11, 21**
 CATS Route Name: **Multiple**

Total Cost: \$ **3400.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	77.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	0.9
Yes	Boarding Area XSlope %	1.6
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	126.0
Yes	PAR 1 Slope %	1.8
No	PAR 1 XSlope %	2.2
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	126.0
No	PAR 2 Slope %	2.7
Yes	PAR 2 XSlope %	0.7
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	2.2
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	77.0
Yes	Clear Floor Space Length (in)	61.0
Yes	Clear Floor Space Slope %	0.9
Yes	Clear Floor Space XSlope %	1.6
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	97.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

