

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10012328	Main Street: DALECREST_DR	Cross Street: N/A	Location: N
ADA ID: 668D6718DD2C	Overall Compliance: No	Severity Score: 65	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Sidewalk To Boarding Area.
Remove or Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.4, R302, R308.1.1.2

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	82.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	6.3
No	Boarding Area XSlope %	4.1
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	No
N/A	Road Slope %	2.3
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	89.0
N/A	Bench?	No
No	Protruding Objects?	Yes

CATS Stop ID: 60050

CATS Stop Description: Dalecrest Dr & Cedarhurst Dr

CATS Route ID: 13

CATS Route Name: Nevin Road

Total Cost: \$ 3250.00

