

Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10041766	Main Street: WILKINSON_BV	Cross Street: N/A	Location: E
ADA ID: 6B8E611739CB	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove or Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

**PIPE PROTRUDING FROM GROUND
BESIDE BENCH**

PROW/ADA:

810.2.2, R308.1.1.1

CATS Stop ID: **45417**

CATS Stop Description: **Wilkinson Blvd & Boyer St**

CATS Route ID: **5**

CATS Route Name: **Sprinter**

Total Cost: \$ **2750.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	161.0
No	Boarding Area Length (in)	72.0
Yes	Boarding Area Slope %	2.0
Yes	Boarding Area XSlope %	3.8
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	83.0
Yes	PAR 1 Slope %	4.3
Yes	PAR 1 XSlope %	1.8
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	5.7
N/A	Shelter	No
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	128.0
Yes	Clear Floor Space Length (in)	70.0
Yes	Clear Floor Space Slope %	0.3
Yes	Clear Floor Space XSlope %	0.4
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

