


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                           |                        |                    |             |
|---------------------------|------------------------|--------------------|-------------|
| Intersection ID: 10016718 | Main Street: ORR_RD    | Cross Street: N/A  | Location: N |
| ADA ID: 6E84946D0871      | Overall Compliance: No | Severity Score: 80 |             |

| Codes/Mitigation Info/Possible Solution | Field Measurements/Component Compliance |
|-----------------------------------------|-----------------------------------------|
|-----------------------------------------|-----------------------------------------|



Possible Solutions:

**Provide Boarding Area. Provide Sidewalk Connection to Boarding Area.**

Surveyor Notes:

**N/A**

PROW/ADA:

**810.2, 810.2.3, R302, R308.1.1**

| Compliance | Description                     | Data |
|------------|---------------------------------|------|
| No         | Boarding Area                   | No   |
| N/A        | Boarding Area Width (in)        | N/A  |
| N/A        | Boarding Area Length (in)       | N/A  |
| N/A        | Boarding Area Slope %           | N/A  |
| N/A        | Boarding Area XSlope %          | N/A  |
| Yes        | PAR 1 Exist?                    | Yes  |
| Yes        | PAR 1 Width (in)                | 59.0 |
| Yes        | PAR 1 Slope %                   | 0.2  |
| Yes        | PAR 1 XSlope %                  | 0.4  |
| N/A        | PAR 1 XSlope Location           | Perp |
| Yes        | PAR 2 Exist?                    | Yes  |
| Yes        | PAR 2 Width (in)                | 59.0 |
| Yes        | PAR 2 Slope %                   | 1.1  |
| Yes        | PAR 2 XSlope %                  | 1.2  |
| N/A        | PAR 2 XSlope Location           | Perp |
| No         | Boarding Area Connected to PAR? | No   |
| N/A        | Road Slope %                    | 0.9  |
| N/A        | Shelter                         | No   |
| N/A        | Clear Floor Space               | No   |
| N/A        | Clear Floor Space Shelter       | No   |
| N/A        | Clear Floor Space Width (in)    | N/A  |
| N/A        | Clear Floor Space Length (in)   | N/A  |
| N/A        | Clear Floor Space Slope %       | N/A  |
| N/A        | Clear Floor Space XSlope %      | N/A  |
| N/A        | Alcove Condition?               | No   |
| Yes        | Transit Sign?                   | Yes  |
| Yes        | Transit Sign Height (in)        | 97.0 |
| N/A        | Bench?                          | No   |
| Yes        | Protruding Objects?             | No   |

CATS Stop ID: 52472

CATS Stop Description: Orr Rd & Pecan Grove Mhp Dr

CATS Route ID: 39

CATS Route Name: Eastway Drive

Total Cost: \$ 1450.00

