


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10040686	Main Street: W_MOREHEAD_ST	Cross Street: N/A	Location: SW
ADA ID: 6F9187B701C5	Overall Compliance: No	Severity Score: 55	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

**NO TRANSIT STOP SIGN IN
MARKER LOCATION. CAN NOT
VERIFY CATS ID.**

PROW/ADA:

810.2.4, R308.1.1.2

CATS Stop ID: N/A
CATS Stop Description: N/A
CATS Route ID: 5
CATS Route Name: **Sprinter**

Total Cost: \$ 750.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	120.0
Yes	Boarding Area Length (in)	141.0
No	Boarding Area Slope %	6.7
No	Boarding Area XSlope %	5.5
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	72.0
Yes	PAR 1 Slope %	2.8
Yes	PAR 1 XSlope %	2.0
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	5.0
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.0
N/A	Bench?	No
Yes	Protruding Objects?	No

