


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10022596	Main Street: CARMEL_RD	Cross Street: N/A	Location: SW
ADA ID: 6FB48C504D50	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

**810.2.2, 810.2.4, R308.1.1.1,
R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	72.0
No	Boarding Area Length (in)	89.0
Yes	Boarding Area Slope %	1.4
No	Boarding Area XSlope %	8.9
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	80.0
Yes	PAR 1 Slope %	0.9
Yes	PAR 1 XSlope %	2.0
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	80.0
N/A	PAR 2 Slope %	6.5
N/A	PAR 2 XSlope %	0.6
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.6
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 04570

CATS Stop Description: Carmel Rd & Camilla Dr

CATS Route ID: 62x

CATS Route Name: Rea Road Express

Total Cost: \$ 750.00

