


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10036971	Main Street: S_TRYON_ST	Cross Street: N/A	Location: N
ADA ID: 733746445AED	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Boarding Area. Provide Sidewalk Connection to Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

810.2, 810.2.3, R302, R308.1.1

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	73.0
Yes	PAR 1 Slope %	1.6
Yes	PAR 1 XSlope %	1.3
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	73.0
Yes	PAR 2 Slope %	1.8
Yes	PAR 2 XSlope %	1.3
N/A	PAR 2 XSlope Location	Perp
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	0.9
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	86.0
Yes	Clear Floor Space Length (in)	74.0
Yes	Clear Floor Space Slope %	1.2
Yes	Clear Floor Space XSlope %	2.0
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 52420

CATS Stop Description: Tryon St & Mother Theresa Villas

CATS Route ID: 16, 41x

CATS Route Name: Multiple

Total Cost: \$ 1450.00

