


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10037850	Main Street: SHARON_RD	Cross Street: N/A	Location: W
ADA ID: 754A281AEF7A	Overall Compliance: No	Severity Score: 80	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Boarding Area. Provide Sidewalk Connection to Boarding Area. Provide Clear Floor Space.

Surveyor Notes:

N/A

PROW/ADA:

810.2, 810.2.3, 810.3, R302, R308.1.1, R404.1

CATS Stop ID: **28840**
 CATS Stop Description: **Sharon Rd & Fairview Rd**
 CATS Route ID: **19**
 CATS Route Name: **Park Road**

Total Cost: \$ **1900.00**

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.4
Yes	PAR 1 XSlope %	1.1
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	1.1
Yes	PAR 2 XSlope %	1.2
N/A	PAR 2 XSlope Location	Perp
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	0.1
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

