


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10032771	Main Street: N_TRYON_ST	Cross Street: N/A	Location: W
ADA ID: 7773607F0CCC	Overall Compliance: No	Severity Score: 25	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space.**

Surveyor Notes:

**UNABLE TO VERIFY CATS ID,
SHELTER LISTS AS CATS TRANSIT
SYSTEM**

PROW/ADA:

**305.2, 402.2, 810.2.3, 810.2.4, 810.3,
R302, R302.6, R308.1.1.2, R404.1,
R404.2**

CATS Stop ID: N/A

CATS Stop Description: N/A

CATS Route ID: 11, 21

CATS Route Name: Multiple

Total Cost: \$ 1950.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	101.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	2.5
Yes	Boarding Area XSlope %	0.4
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	145.0
No	PAR 1 Slope %	3.4
Yes	PAR 1 XSlope %	1.8
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	145.0
Yes	PAR 2 Slope %	1.6
Yes	PAR 2 XSlope %	1.5
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.6
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	101.0
Yes	Clear Floor Space Length (in)	61.0
No	Clear Floor Space Slope %	2.5
Yes	Clear Floor Space XSlope %	0.4
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	97.0
N/A	Bench?	No
Yes	Protruding Objects?	No

