


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10011551	Main Street: THE_PLAZA	Cross Street: N/A	Location: N
ADA ID: 7782E93D153C	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, R302, R302.6

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	114.0
Yes	Boarding Area Slope %	1.8
Yes	Boarding Area XSlope %	1.4
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	72.0
Yes	PAR 1 Slope %	1.4
Yes	PAR 1 XSlope %	1.8
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	72.0
Yes	PAR 2 Slope %	2.0
No	PAR 2 XSlope %	3.0
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.3
N/A	Shelter	No
N/A	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	243.0
N/A	Clear Floor Space Length (in)	35.0
N/A	Clear Floor Space Slope %	0.5
N/A	Clear Floor Space XSlope %	0.4
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 31450

CATS Stop Description: The Plaza & Sweetbriar St

CATS Route ID: 3, 4

CATS Route Name: Multiple

Total Cost: \$ 700.00

