


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10037393	Main Street: SCALEYBARK_RD	Cross Street: N/A	Location: W
ADA ID: 7BD5132F02F2	Overall Compliance: N/A	Severity Score: 10	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

N/A

Surveyor Notes:

N/A

PROW/ADA:

N/A

CATS Stop ID: 46288

CATS Stop Description: Scaleybark Rd & Falls Creek Ln

CATS Route ID: 30

CATS Route Name: Woodlawn Crosstown

Total Cost: \$0.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	0.6
Yes	Boarding Area XSlope %	0.5
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	2.0
Yes	PAR 1 XSlope %	0.2
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.4
Yes	PAR 2 XSlope %	0.2
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.8
N/A	Shelter	No
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	45.0
Yes	Clear Floor Space Length (in)	48.0
Yes	Clear Floor Space Slope %	0.4
Yes	Clear Floor Space XSlope %	0.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

