


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10041339	Main Street: WEST_BV	Cross Street: N/A	Location: S
ADA ID: 7D240EF414ED	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 403.5.1, R302, R302.3

CATS Stop ID: **34540**

CATS Stop Description: **West Blvd & Amay James Ave**

CATS Route ID: **10, 235**

CATS Route Name: **Multiple**

Total Cost: \$ **1400.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	81.0
Yes	Boarding Area Length (in)	124.0
Yes	Boarding Area Slope %	1.4
Yes	Boarding Area XSlope %	0.3
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	47.0
Yes	PAR 1 Slope %	0.7
Yes	PAR 1 XSlope %	1.2
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
No	PAR 2 Width (in)	47.0
Yes	PAR 2 Slope %	0.8
Yes	PAR 2 XSlope %	1.7
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.7
N/A	Shelter	No
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	75.0
Yes	Clear Floor Space Length (in)	58.0
Yes	Clear Floor Space Slope %	0.1
Yes	Clear Floor Space XSlope %	0.1
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

