


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                           |                                         |             |
|-----------------------------------------|---------------------------|-----------------------------------------|-------------|
| Intersection ID: 10041767               | Main Street: WILKINSON_BV | Cross Street: N/A                       | Location: S |
| ADA ID: 7D9DC603A9F7                    | Overall Compliance: No    | Severity Score: 20                      |             |
| Codes/Mitigation Info/Possible Solution |                           | Field Measurements/Component Compliance |             |



Possible Solutions:

**Remove & Replace Boarding Area.  
Remove & Replace Sidewalk To  
Boarding Area. Remove or Relocate  
Protruding Objects/Obstructions.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, 810.2.3, 810.2.4, R302, R302.5,  
R302.6, R308.1.1.2**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| Yes        | Boarding Area                   | Yes   |
| Yes        | Boarding Area Width (in)        | 120.0 |
| Yes        | Boarding Area Length (in)       | 102.0 |
| No         | Boarding Area Slope %           | 2.6   |
| No         | Boarding Area XSlope %          | 4.2   |
| No         | PAR 1 Exist?                    | Yes   |
| Yes        | PAR 1 Width (in)                | 72.0  |
| No         | PAR 1 Slope %                   | 5.0   |
| No         | PAR 1 XSlope %                  | 2.3   |
| N/A        | PAR 1 XSlope Location           | Perp  |
| No         | PAR 2 Exist?                    | Yes   |
| Yes        | PAR 2 Width (in)                | 72.0  |
| No         | PAR 2 Slope %                   | 4.8   |
| No         | PAR 2 XSlope %                  | 2.2   |
| N/A        | PAR 2 XSlope Location           | Perp  |
| Yes        | Boarding Area Connected to PAR? | Yes   |
| N/A        | Road Slope %                    | 3.8   |
| N/A        | Shelter                         | Yes   |
| Yes        | Clear Floor Space               | Yes   |
| N/A        | Clear Floor Space Shelter       | Yes   |
| Yes        | Clear Floor Space Width (in)    | 50.0  |
| Yes        | Clear Floor Space Length (in)   | 61.0  |
| Yes        | Clear Floor Space Slope %       | 1.0   |
| Yes        | Clear Floor Space XSlope %      | 1.0   |
| N/A        | Alcove Condition?               | Yes   |
| Yes        | Transit Sign?                   | Yes   |
| Yes        | Transit Sign Height (in)        | 97.0  |
| N/A        | Bench?                          | Yes   |
| No         | Protruding Objects?             | Yes   |

CATS Stop ID: 35310

CATS Stop Description: Wilkinson Blvd & Boyer St

CATS Route ID: 235, 5

CATS Route Name: Multiple

Total Cost: \$ 4150.00

