


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10039999	Main Street: TRINITY_RD	Cross Street: N/A	Location: N
ADA ID: 7ECE47AE1696	Overall Compliance: No	Severity Score: 20	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Remove & Replace
Clear Floor Space. Remove or
Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 402.2, 810.2.2, 810.2.3, 810.3,
R302, R302.6, R308.1.1.1, R404.1,
R404.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	115.0
No	Boarding Area Length (in)	53.0
Yes	Boarding Area Slope %	1.6
Yes	Boarding Area XSlope %	1.0
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	48.0
No	PAR 1 Slope %	2.8
Yes	PAR 1 XSlope %	1.2
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	48.0
Yes	PAR 2 Slope %	1.1
No	PAR 2 XSlope %	2.1
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.4
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	64.0
Yes	Clear Floor Space Length (in)	60.0
No	Clear Floor Space Slope %	4.5
No	Clear Floor Space XSlope %	2.8
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	88.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 42515

CATS Stop Description: Trinity Rd @ 9115

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$ 4650.00

