




Access Compliance Report Public Rights-of-Way (Transit Stops)



Intersection ID: 1001804	Main Street: PROSPERITY_CHURCH_RD	Cross Street: N/A	Location: W
ADA ID: 836863D629D0	Overall Compliance: No	Severity Score: 50	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

**810.2.2, 810.2.4, R308.1.1.1,
R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	103.0
No	Boarding Area Length (in)	74.5
No	Boarding Area Slope %	6.9
No	Boarding Area XSlope %	2.6
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	103.0
Yes	PAR 1 Slope %	1.2
Yes	PAR 1 XSlope %	1.1
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.5
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: **46730**

CATS Stop Description: **Prosperity Church Rd & Panthersville Dr**

CATS Route ID: **59**

CATS Route Name: **North Meck Connector**

Total Cost: \$ **750.00**

